

Item Cover Page

CITY COUNCIL MEETING AGENDA ITEM REPORT

DATE: November 6, 2024

SUBMITTED BY: Kim Clayback, Public Works & Utilities

ITEM TYPE: Contract

AGENDA SECTION: CONSENT AGENDA

SUBJECT: Lift Station 4 Repair and Rehabilitation

SUGGESTED ACTION: Approval of attached estimate and invoice for the total project cost for the repair.

Is this item Quasi-Judicial?

No

Does this item require a public hearing?

No

EXPLANATION:

During Tropical Storm Debby, the internal piping to LS04 failed and caused the drywell portion of the lift station to flood and compromise the pumps. The lift station has been on emergency bypass while the repair parts and pumps have been on order. One attachment is for the bypass pumping costs through September 30, 2024; the second attachment is for the repair and rehab of the station to include valving required for the repair, additional bypass pumping, and piping.

FINANCIAL IMPACT:

The repair and rehab are budgeted in 40859000-563000-25506, approved by Council in September 2024.

SUGGESTED MOTION:

Motion to approve Lift Station 4 repair and rehabilitation as presented.

ATTACHMENTS:

[Billing Summary from Bearing Point Construction, LLC](#)
[Proposal from Bearing Point Construction, LLC](#)