

Item Cover Page

CITY COUNCIL MEETING AGENDA ITEM REPORT

DATE: December 18, 2024

SUBMITTED BY: Kim Clayback, Public Works & Utilities

ITEM TYPE: Contract

AGENDA SECTION: CONSENT AGENDA

SUBJECT: Lift Station 14 Improvements

SUGGESTED ACTION: Council approval for work assignment for Bearing Point to install the isolation transformer and lighting/surge protection.

Is this item Quasi-Judicial?

No

Does this item require a public hearing?

No

EXPLANATION:

Power fluctuations and electrical surges experienced at the lift station have caused equipment to burn out and power failure at this critical location. The isolation transformer will better regulate the power flow into the station and lightning/surge protection will help protect sensitive electronic equipment.

Work is authorized using PB 21-01KC EX01, approved by Council on 02-08-2023 and expires 01-30-2026.

FINANCIAL IMPACT:

ARPA money is being utilized for this improvement and will be encumbered in GL acct 30358200-563000-LS14.

ATTORNEY REVIEW/RECOMMENDATION:

N/A

SUGGESTED MOTION:

Motion to approve the work assignment for improvements at LS14.

ATTACHMENTS:

Proposal from Bearing Point Construction, LLC