# Item Cover Page

#### **CITY COUNCIL MEETING AGENDA ITEM REPORT**

DATE:November 6, 2024SUBMITTED BY:Kim Clayback, Public Works & UtilitiesITEM TYPE:ContractAGENDA SECTION:CONSENT AGENDASUBJECT:Pipe Lining Work Assignment in the LS23 SewershedSUGGESTED ACTION:Approval of the attached work assignment for<br/>Insituform to clean, camera, and line sanitary sewer<br/>gravity mains in the LS23 sewershed.

Is this item Quasi-Judicial? No

**Does this item require a public hearing?** No

#### **EXPLANATION:**

The City is actively working to clean, camera, and line sanitary sewer pipe that has reached the end of its useful life; the pipe targeted for lining is old, vitrified clay pipe installed prior to 1970. Lining is far less intrusive than a full pipe replacement and more cost effective; generally, lining a pipe provides another 40 -50 years of useful life to the pipe. The lining decreases the opportunity for infiltration via groundwater into the system thereby reducing flows to the water reclamation facility.

#### FINANCIAL IMPACT:

The overall project budget was approved by Council in September 2024 and will be encumbered in GL account 40859000-563000-25504.

#### ATTORNEY REVIEW/RECOMMENDATION:

### **SUGGESTED MOTION:**

Motion to approve pipe lining work assignment in the LS23 Sewershed.

## **ATTACHMENTS:**

Insituform Proposal Pipe Lining Map

NA