

Item Cover Page

CITY COUNCIL MEETING AGENDA ITEM REPORT

DATE: July 22, 2026

SUBMITTED BY: Kristofer Eccles, Public Works & Utilities

ITEM TYPE: Contract

AGENDA SECTION: CONSENT AGENDA

SUBJECT: Work Assignment for Upgrades at Lift Stations 2, 4, 10, 27, and 35

SUGGESTED ACTION: Approval

Is this item Quasi-Judicial?

No

Does this item require a public hearing?

No

EXPLANATION:

This work assignment is to replace control panels, deteriorated electrical panels, and associated equipment at five of the City's lift stations: LS02, LS04, LS10, LS27, and LS35. These improvements are necessary to enhance the reliability, operational performance, and resilience of the lift stations. This work assignment also includes connecting a standby bypass pump at LS35. The standby bypass pump will provide additional system redundancy and help prevent sanitary sewer overflows in the event of a power outage, pump failure, or other equipment failure at the lift station.

FINANCIAL IMPACT:

Funded by GL account (40859000-563000-26506).

ATTORNEY REVIEW/RECOMMENDATION:

N/A

SUGGESTED MOTION:

Motion to approve the work assignment for Upgrades at Lift Stations 2, 4, 10, 27, and 35.

ATTACHMENTS:

Work Assignment for Upgrades at Lift Stations 2, 4, 10, 27, and 35