

**Plantation City Council/CRA Notice of City Council/CRA
Meeting Agenda Meeting**

July 29, 2026



City of Plantation
City Council Chambers

Subject:

ITB No. 014-26: Central Water Treatment Plant (CWTP) & East Water Treatment Plant (EWTP) Degasser Media Replacement

Summary:

Requesting authorization and approval of the following:

Authorization and approval to issue a purchase order and process payment(s) to Fehl Safe Water Systems LLC in accordance with scope of work, terms and conditions of ITB No. 014-26; CWTP & EWTP Degasser Media Replacement for an amount of \$199,500.00.

Procurement:

Pursuant to City Code Sec. 2-220(e), the Procurement Department secured formal competitive bids for the above-mentioned services. On June 2, 2026, there were a total of twenty-eight (28) planholders for this solicitation, and four (4) competitive bids were received (in which one was deemed non-responsive), broadcast to 2067 vendors. This solicitation was advertised/posted on the Demand Star website for thirty-five (35) calendar days. A copy of the three (3) competitive bids are attached for your review.

The numerical results are as followed:

<u>Vendor</u>	<u>Base Bid Total</u>	<u>Plantation Local Business pursuant to Section 2-227 City Code</u>
	-	
Fehl Safe Water Systems	\$199,500.00	No
Florida Utility Solutions, LLC	\$220,979.20	No
Intercounty Engineering, Inc.	\$388,864.00	No
Razorback, LLC	Non-responsive (Vendor Failed to Upload Bid Documents)	

The Procurement Department staff performed a review of the apparent low bidder (Fehl Safe Water Systems LLC) to ascertain submittal responsiveness. After careful consideration of all the information provided by the bidder, the Procurement Department staff concluded that Fehl Safe Water Systems LLC (the apparent low bidder) submitted the lowest, responsive bid submittal.

The Utilities Department staff performed a review of the lowest responsive bid(der) to ascertain if they were responsible. After careful consideration of all the information provided, the Utilities Department staff has concluded that Fehl Safe Water Systems was the lowest responsible bidder.

Based on the foregoing, the Utilities and Procurement Departments request authorization and approval of the following:

- Authorization and approval to issue a purchase order and process payment(s) to Fehl Safe Water Systems LLC in accordance with scope of work, terms and conditions of ITB No. 014-26; CWTP & EWTP Degasser Media Replacement for an amount of \$199,500.00.

Background:

Strategic Priorities: Proactive and Responsive Asset Management

Degasser Media is replaced every 7years per the recommendation of the Water Master Plan. Utilization of Tri-Packs in the degasifier towers provide for effective air-stripping of hydrogen sulfide & carbon dioxide from the drinking water.

This item is now ready for City Council consideration.

Funding:

443-0000-169-9637 CIP-CWTP & EWTP Degasser Media Project #1057

Amount:

\$199,500.00

Finance Director/Budget Manager Recommendation:

The Utilities Repair & Replacement Fund has a total of \$275,000 in the FY2026 Budget for the CWTP & EWTP Degasser Media Replacement (Project #1057).

Prepared By:

Asha Edwards

ATTACHMENTS:

[ITB No. 014-26](#)

[Fehl Safe Water Bid Submittal](#)

[FL Utility Soln Bid Submittal](#)

[Intercounty Eng Bid Submittal](#)