

**AGENDA # K.6**  
**Scio Township Board of Trustees**  
**Wagner Booster Station Repair of Pump #2**

**FOR MEETING DATE OF:** March 10, 2026

**PREPARED ON:** 3/2/2026

**PREPARED BY:** Brandon McNiel

**SUBMITTED BY:** Utilities

**ITEM TYPE:** Possible Action

**SUGGESTED ACTION:** To authorize Kennedy Industries to repair pump #2 at Wagner Booster Station

**BACKGROUND:** Upon inspection of the booster station, the Utilities Department noticed a leak in one of the pumps. Kennedy Industries was called to assess the issue and removed the pump for inspection. After inspection, several issues were identified as outlined in the attached quote. The pump is needed for redundancy to ensure water is pumped properly throughout the system.

**FISCAL IMPACT:** \$8850.00 from GL #591-000-935.000

**RECOMMENDATION:** Utility Director/Supervisor recommend repair of pump.

**MODEL MOTION:** Authorize Kennedy Industries to complete the necessary repairs to pump #2 not to exceed \$8,850.00 from GL #591.000.935.000.

**ATTACHMENTS:**

[Kennedy Industries quote.pdf](#)

**QUESTION:** Shall this Motion be APPROVED?