

Memorandum

TO: City Council
FROM: Jamie Meyer , Utilities Supervisor
DATE: August 17, 2026
SUBJECT: Accept quote from Quality Flow Systems for the replacement of the Suzanne stormwater lift station control panel
ITEM NUMBER: 8.j
SECTION: CONSENT AGENDA

REQUESTED MOTION

To accept the quote from Quality Flow Systems in the amount of \$34,920 for the replacement Suzanne stormwater lift station control panel.

INTRODUCTION

Staff has solicited a quote to complete the replacement of the control panel of the Suzanne stormwater lift station and city council authorization is required to purchase and install the cabinet.

DISCUSSION

The control panel for the Suzanne stormwater lift station is nearing the end of its useful life with replacement parts and is becoming obsolete. To prevent the risk of failure of the lift station, the replacement of the current control panel is required.

Staff has solicited a quote from Quality Flow Systems in the amount of \$34,920 to replace the lift station control panel. A copy of the quote is located at the end of the report. The city typically works with Quality Flow Systems for all troubleshooting and repairs, part replacement, and upgrades for lift stations. Quality Flow supplies pumps and controls for municipal applications to many cities in the metro area and surrounding states. Standardizing the lift station pumps and controls has simplified operational use, streamlined troubleshooting and repair, and allowed for interchangeable components and spare parts. As a result, maintenance efficiency is improved, training requirements reduced, and overall system reliability increased.

Funding for the replacement will come from the surface water fund.

RECOMMENDATION

It is recommended that the city council accept the quote from Quality Flow Systems in the amount of \$34,920 for the replacement of the Suzanne stormwater lift station.

ATTACHMENTS

[Quality Flow quote](#)