

Memorandum

TO: City Council
FROM: Todd Jagoe , Utilities Supervisor
DATE: February 17, 2026
SUBJECT: Accept the quote from Quality Flow Systems to replace the control panels at (#1) North Lexington and (#16) South Lexington lift stations.
ITEM NUMBER: 8.f
SECTION: CONSENT AGENDA

REQUESTED MOTION

To accept the quote from Quality Flow Systems in the combined amount of \$84,310.00 to replace the control panel cabinets in lift station #1(North Lexington) and #16(South Lexington).

INTRODUCTION

Staff has solicited a quote to complete the replacement and installation of two new control panel cabinets and city council authorization is required to purchase and install the cabinets.

DISCUSSION

All of the city's lift stations are inspected in the spring and fall of each year and staff has determined that certain components are in need of repair or replacement. The current five year capital improvement plan includes annual funding to complete the sanitary sewer lift station improvements.

The control panels for the North and South Lexington lift stations are nearing the end of their useful life with replacement parts that are becoming obsolete. To prevent the risk of failures at these two high flow lift stations, the replacement of the current control panels is required.

Staff received quotes from Quality Flow Systems in the amount of \$41,600.00 for (#1)North Lexington lift station and \$42,710.00 for (#2)South Lexington lift station for a total of \$84,310.00. Copies of the two quotes are attached at the end of this report. The city has typically worked with Quality Flow Systems for all troubleshooting and repairs, part replacement, and upgrades for lift stations. Quality Flow supplies pumps and controls for municipal applications to many cities in the metro area and surrounding states. Standardizing the lift station pumps and controls has simplified operational use, streamlined troubleshooting and repair, and allowed for interchangeable components and spare parts. As a result, maintenance efficiency is improved, training requirements reduced, and overall system reliability increased.

The lift station improvements would be funded from the sewer fund.

RECOMMENDATION

It is recommended that the city council accept the quotes from Quality Flow Systems in the total amount of \$84,310.00 for the purchase and installation of the #1(North Lexington) and #16(South Lexington) lift station control panels.

ATTACHMENTS

[South Lexington Panel Quote 2026](#)

[North Lexington Panel Quote 2026](#)