



# Weatherford Municipal Utility Board

---

## AGENDA REPORT

**Meeting Date:** March 30, 2023

**Staff Contact:** Bill Smith, Assistant Director of Engineering

**Item Number:** 2023-151-AR

**Phone:** 817-598-4033

---

**SUBJECT:** Consider authorizing the City Manager to execute a professional services contract with Garver, LLC for design of the Town Creek Wastewater Interceptor Improvements project in the amount not to exceed \$358,500.00.

---

### **BACKGROUND/DISCUSSION**

In an effort to improve the conveyance of one of the City's largest wastewater mains, Staff identified a section of the Town Creek wastewater interceptor that is in need of improvement. This portion of wastewater line is included in the City's 2017 Wastewater Master Plan. Garver previously prepared the Weatherford Town Creek Interceptor Hydraulic Analysis Technical Memorandum in 2022, which identifies this section of wastewater main to be in need of improvement.

In 2022, Staff issued a Request for Qualifications (RFQ) for Water and Wastewater System Master Planning and Design. Garver was one of the consultants that was selected with the RFQ, and staff has found them to be qualified to complete the design of the project.

Approximately 5,080 linear feet of existing 18" clay line will be replaced by a 36" PVC line, along with the installation of any associated appurtenances and manholes. The design of the project is expected to take approximately 12 months, and construction is targeted to begin shortly thereafter.

### **FINANCIAL IMPACT**

Design of this project will be funded with currently available funds from utility rate revenues.

### **SUGGESTED ACTION**

Staff recommends authorizing the City Manager to execute a professional services contract with Garver, LLC for design of the Town Creek Wastewater Interceptor Improvements project in the amount not to exceed \$358,500.00.

### **ATTACHMENTS**

- [Project Map Town Creek Wastewater Interceptor Improvements.pdf](#)
- [FINAL Standard Engineering Services Contract - Garver\\_.pdf](#)